	Building Energy Performance				Scotland		
Energy Performance Certificate	Calculated asset rating using iSBEM v3.4.a [SBEM]	Building type Workshops/maintenance depot		epot	Current rating		
		Ca	rbon Neutr	al	E	ccellent	
		A	(0 to 15)				
		В					
		_	(16 to 30)				
		C	(31 to 45)				
		D -	(46 to 60)			D+	
		Ε_	(61 to 80)				
rfc		F	(81 to 100)				
Pe		G	(100+)		Ve	ry Poor	
Energy	Carbon Dioxide Emissions The number refers to the calculated carbon dioxide emissions in terms of kg per m² of floor area per year			47			
	Approximate current energy use per m² of floor area:				148 kWh/m²		
	Main heating fuel: Natural Gas Renewable energy source:	Building Services: Heatin			ng with Nat. Vent.		
	Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.						
Benchmarks							
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating: 49						D+	
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating: ??							
Recommendations for the cost-effective improvement (lower cost measures) of the energy performance							
Some spaces have a significant risk of overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows. 4. Install more efficient water heater.							
Add time control to heating system. 5. Add local temperature control to the heating system.						system.	
3. Add optimum start/stop to the heating system. 6. Add weather compensation controls to heating system.							
	Address: Linit 6 Grange Court Industrial Forts Gate Park Grangemouth						

Address: Unit 6, Grange Court Industrial, Earls Gate Park, Grangemouth

Conditioned area (m²): 160

Name of protocol organisation: Northgate Land and Property Solutions Ltd, [00000034555]

Date of issue of certificate: 11 Aug 2009 (Valid for a period not exceeding 10 years)

This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.

NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE